

Concise Latest Test Results



SEAWARD
ELECTRICAL SAFETY TESTING & MEASURING.

Test Status: All, Test Type: All
Person: All, Instrument: All
From: 08/01/2024 To: 12/04/2024

Site: 029724

Location: OFFICE

Asset ID	Description	User	Test Instrument	Date	Retest Period	Next Test	Result
982	IEC LEAD	C CUTTS	Seaward Apollo 500 Plus V00-0000	12/04/2024	12 Months	12/04/2025	Pass
983	SPEAKER	C CUTTS	Seaward Apollo 500 Plus V00-0000	12/04/2024	12 Months	12/04/2025	Pass
984	IEC LEAD	C CUTTS	Seaward Apollo 500 Plus V00-0000	12/04/2024	12 Months	12/04/2025	Pass
985	PSU	C CUTTS	Seaward Apollo 500 Plus V00-0000	12/04/2024	12 Months	12/04/2025	Pass
986	PSU	C CUTTS	Seaward Apollo 500 Plus V00-0000	12/04/2024	12 Months	12/04/2025	Pass
987	AC ADAPTER	C CUTTS	Seaward Apollo 500 Plus V00-0000	12/04/2024	12 Months	12/04/2025	Pass
988	AC ADAPTER	C CUTTS	Seaward Apollo 500 Plus V00-0000	12/04/2024	12 Months	12/04/2025	Pass
989	AC ADAPTER	C CUTTS	Seaward Apollo 500 Plus V00-0000	12/04/2024	12 Months	12/04/2025	Pass
990	AC ADAPTER	C CUTTS	Seaward Apollo 500 Plus V00-0000	12/04/2024	12 Months	12/04/2025	Pass
991	EXTENSION LEAD	C CUTTS	Seaward Apollo 500 Plus V00-0000	12/04/2024	12 Months	12/04/2025	Pass
992	EXTENSION LEAD	C CUTTS	Seaward Apollo 500 Plus V00-0000	12/04/2024	12 Months	12/04/2025	Pass

Total Tests: 11